



MAR ATHANASIOUS COLLEGE OF ENGINEERING
KOTHAMANGALAM COLLEGE P.O.,
KOTHAMANGALAM T.O.
KERALA- 686666, Ph: 0485 2822363

PRINCIPAL

Receipt No. ETR001 034475 202324

(ORIGINAL/DUPLICATE)

Date: 01/8/23

To, Assistant Executive Engineer, Project Sub Division Thodupuzha

Ref: Letter No. AEE/JJM/ARK/2022-23 dated 31/7/23 (JJM-WSS to Arakkulam Panchayath Part-II in Idukki District- Construction of well cum pump house, retaining wall & foot bridge)

Sir,

The following are the results of the tests conducted on the specimens supplied by you on date:31/7/23

COMPRESSION TESTS ON CONCRETE SPECIMENS

Sl. No.	Details of specimen		Breaking load (t)	Compressive strength N/mm ²	Weight (kg)	Remarks
I	Compression test on concrete cubes Dimension: 15 cm x15 cm x 15 cm Grade: M25 Casting Date : 30/6/23	1	82.5	35.9	8.316	
		2	90.0	39.2	8.214	
		3	69.5	30.3	8.402	

The tests were carried out on


01/8/23

at room temperature 30°C
of

Tested by: Sara Roshan

Certified by Asst. Prof. Berlin Sabu

Verified by: Dr. Elson John (H.O.D Civil)



Yours faithfully,

[Signature]
PRINCIPAL