



PRINCIPAL

MAR ATHANASIOUS COLLEGE OF ENGINEERING

KOTHAMANGALAM COLLEGE P.O.,

KOTHAMANGALAM T.O.

KERALA- 686666, Ph: 0485 2822363

Receipt No. ETR001133241202324

(ORIGINAL/DUPLICATE)

Date: 11/08/2023

To, Assistant Engineer KWA Project Division Thodupuzha.

Ref. Your letter No: AEE/JJM/ARK/2022-23 dated 09/08/2023(JJM-WSS to Arakkulam Panchayath Part-II in Idukki District Construction of Well cum Pump house, Retaining wall & foot bridge)

Sir,


The following are the results of the tests conducted on the specimens supplied by you on date: 10/08/2023.

COMPRESSION TESTS ON CONCRETE SPECIMENS

Sl. No.	Details of specimen		Breaking load (t)	Compressive strength N/mm ²	Weight (Kg)	Remarks
1	Compression test on Concrete Cubes Dimension :15 cm x 15 cm x 15cm Grade: M25 Casting Date : 10/07/2023	1	80.0	34.8	8.402	
		2	74.5	32.4	8.314	
		3	70.0	30.5	8.368	

The tests were carried out on 11/08/2023

Tested by: *Sara Resha*
Certified by: Assistant Professor Eldhose M Manjummekudiyil
Verified by: Dr. Elson John (H.O.D Civil)



at room temperature of 30 °C
Yours faithfully,

[Signature]
PRINCIPAL.