


INSPECTION REPORT			
IR NO.	MI/JJM-KWA/PALAKKAD/2020-21/676	DATE	27.03.2023
CLIENT	M/s. KERALA WATER AUTHORITY	CONTRACTOR	Sri.PAULOSE.K. I
CONTRACTOR'S PO/Agreement No.	01/2022-23/SE/PHC/PKD dt:07/04/2022	DISTRICT	PALAKKAD
		HABITATION/ PANCHAYATH	KARAKURISSI
		DIVISION.	PROJECT DIVISION PALAKKAD
MOODY AGREEMENT NO.	KWA/PD/CTR/DB-858/2021JJM/TPI	DATE	03.02.2021
NAME OF THE WORK	Jal Jeevan mission-2020-21-Wss to Karakurissi panchayath-supplying, laying, testing,commissioning and maintenance of distribution system with providing FHTCs(2623 Nos)		
VALUE OF THE WORK	Agreement Amount: Rs.11,50,04,526/- Value of work inspected: Rs.89,77,233/-		
SCOPE OF WORK	1. Sample check of Documents ( TC's) 2. Quality & Quantity check as per bills submitted 3. Functioning of works (FHTCs/Infrastructure Facilities)	Dates of Inspection	25.03.2023
INSPECTION CARRIED OUT	<input type="checkbox"/> Complete POWORK	<input checked="" type="checkbox"/> Partial POWORK	<input type="checkbox"/> Balance POWORK
<p><b>INSPECTION ACTIVITIES: Site inspection carried out and the details of inspection are as follows :</b></p> <ul style="list-style-type: none"> <li>• CC 6<sup>th</sup> and Part bill contractor verified and found tallying as per work order/agreement given.</li> <li>• 228 Nos FHTCs inspection carried out.</li> <li>• Non-ISI PVC water taps used in FHTCs</li> <li>• FHTCs found with 15mm (1/2 inch) house connection with 15mm water meter provided.</li> <li>• FHTCs found with 15mm PVC tap in the water meter assembly observed.</li> <li>• Found earth excavation and CC &amp; BT road cutting.</li> <li>• Laying of 11.79 km found to be satisfactory.</li> <li>• Visual inspection carried out for completeness and found to be satisfactory.</li> <li>• Workmanship and finish found to be satisfactory.</li> </ul>			
<p><b>Note:</b> This Inspection Report does not relieve the Contractor from any responsibility, or any contractual obligations or guarantees, not shall it be interpreted in any way so as to imply acceptance of the goods/works. Inspection is performed to the best of our ability, knowledge and belief but our organization shall not be held responsible in any way whatsoever for the content of or technical accuracy of the purchase order/Agreement.</p>			
DATE : 27.03.2023 PLACE: Hyderabad		 For MOODY INTERNATIONAL INDIA PVT.LTD	

## INSPECTION PHOTOGRAPHS

### Inspections (Fhtcs, Distribution, Supply)

