


INSPECTION REPORT			
IR NO.	MI/JJM-KWA/PALAKKAD/2020-21/680	DATE	22.03.2023
CLIENT	M/s. KERALA WATER AUTHORITY	CONTRACTOR	M/s C T. THAMBI
CONTRACTOR'S PO/Agreement No.	4/2021-22/SE/PHC/PKD, Dated.13.04.2021	DISTRICT	PALAKKAD
		HABITATION/PANCHAYATH	VANIYAMKULAM
		DIVISION.	PROJECT DIVISION PALAKKAD
MOODY AGREEMENT NO.	Work Order No. KWA/PD/CTR/DB-858/2021JJM/TPI	DATE	03.02.2021
NAME OF THE WORK	JJM – 2020-21 Supplying, Laying, Testing, Commissioning & Maintenance of Distribution system and Providing FHTC'S (7541 No's) in Vaniyamkulam Grama Panchayath.		
VALUE OF THE WORK	Agreement Amount: Rs.18,51,42,294/- Value of work inspected: Rs.1,20,26,108/- 12 <sup>th</sup> Part bill		
SCOPE OF WORK	1. Sample check of Documents ( TC's) 2. Quality & Quantity check as per bills submitted 3. Functioning of works (FHTCs/Infrastructure Facilities)	Dates of Inspection	09.02.2023
INSPECTION CARRIED OUT	<input type="checkbox"/> Complete PO WORK	<input checked="" type="checkbox"/> Partial PO WORK	<input type="checkbox"/> Balance PO WORK
<p><b>INSPECTION ACTIVITIES: Site inspection carried out ( FHTCs on sampling basis) and the details of inspection are as follows :</b></p> <ul style="list-style-type: none"> <li>• CC 12<sup>th</sup> Part of Bill contractor verified and found tallying as per work order/agreement given by KWA.</li> <li>• Found earth excavation and CC &amp; BT road cutting &amp; Laying.</li> <li>• Non-ISI PVC Taps used for the HTC's.</li> <li>• 188 Nos HTC's inspection carried out and Laying of 24.21km(350mm,450mm,50mm DI Pipes)</li> <li>• HTC's found with 15mm (1/2 inch) house connection with 15mm water meter provided.</li> <li>• HTC's found with 15mm PVC tap in the water meter assembly observed.</li> <li>• Visual inspection carried out for completeness and found to be satisfactory.</li> <li>• Workmanship and finishing found to be satisfactory.</li> </ul>			
<p><b>Note:</b> This Inspection Report does not relieve the Contractor from any responsibility, or any contractual obligations or guarantees, not shall it be interpreted in any way so as to imply acceptance of the goods/works. Inspection is performed to the best of our ability, knowledge and belief but our organisation shall not be held responsible in any way whatsoever for the content of or technical accuracy of the purchase order/Agreement.</p>			
DATE : 22.03.2023 PLACE: Hyderabad		 For MOODY INTERNATIONAL INDIA PVT.LTD	

## INSPECTION PHOTOGRAPHS

### Inspection of FHTCs





**Moody International India Pvt. Ltd, No. 719 B, 7th Floor , Manjeera Majestic Commercial, JNTUH-Hitech City Road, Beside Raythu Bazar, Hyderabad, Telangana- 500072, Board No. : 91 40 40262264, 65, Fax: +91 04 40262266**